



# ADA TITLE II ASSESSMENT



Prepared for:

**Montgomery County Public Schools**  
45 West Gude Drive, Suite 4100  
Rockville, Maryland 20850

## ADA TITLE II ASSESSMENT

Jackson Road Elementary  
900 Jackson Road  
Silver Spring, Maryland 20904

### PREPARED BY:

EMG  
10461 Mill Run Circle, Suite 1100  
Owings Mills, Maryland 21117  
800.733.0660  
[www.EMGcorp.com](http://www.EMGcorp.com)

### EMG CONTACT:

Michael Nelson  
Program Manager  
800.733.0660 x6244  
[mnelson@emgcorp.com](mailto:mnelson@emgcorp.com)

**EMG Project Number:**

123821.17R000-055.303

**Date of Report:**

October 24, 2019

**On Site Date:**

September 11, 2017



# 1 Accessibility

Generally, Title II of the Americans with Disabilities Act (ADA) prohibits discrimination by entities to access and use of the government entity’s programs, services, and facilities on the basis of disability. Regardless of their age, these areas and facilities must be maintained and operated to comply with the Americans with Disabilities Act Accessibility Guidelines (ADAAG), and applicable state and local accessibility regulations.

Buildings completed and occupied after January 26, 1992 are required to comply fully with ADAAG. Existing facilities constructed prior to this date are held to the lesser standard of complying to the extent allowed by structural feasibility and the financial resources available, or a reasonable accommodation must be made. The ADA guidelines were clarified and amended in 2010 based on a clarification by the Department of Justice known as the “2011 Site Construction Tolerances Addendum to the 2010 ADA Standards for Accessible Design.” The aforementioned document defines the acceptable and allowed construction tolerances above or below the requirements established in the 2010 ADA Standards for barriers related to:

- Accessible Parking
- Pedestrian Path of Travel
- Building Entrances
- Interior Spaces

The scope of the ADA Assessment, as defined in the scope of work, is limited to exterior and interior areas covered by the ADA.

Based on the onsite review, EMG found that barriers to accessibility exist at Jackson Road Elementary School. The observed elements were analyzed using the 2010 ADA Standards for Accessible Design and state accessibility codes.

## 1.1 Accessibility Summary Table

Based on the onsite review, EMG found that barriers to accessibility exist at Jackson Road Elementary School. The observed elements were analyzed using the 2010 ADA Standards for Accessible Design and state accessibility codes.

EMG’s assessment of the subject property identified the following areas of concern:

Facility / Building	Priority 1 Items	Priority 2 Items	Priority 3 Items	Priority 4 Items	Priority 5 Items	Total Items
Jackson Road Elementary School	77	21	69	15		182
Grand Total	77	21	69	15		182

## 1.2 Barrier Summary Table

The following table summarizes the barriers that were identified. The costs provided are order of magnitude estimates. Costs will vary depending upon the location and volume of work performed. Individual observation details may be found in Appendix A.



Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
78862	Jackson Road Elementary School	EXTERIOR	Entrance to Building	Building Entrance-Door	1	The maneuvering clearance at the accessible door is not level and clear.	Exterior Door 1	ADA
78863	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk from Exterior Door 1 to Southwest Corner of the School.	ADA
78865	Jackson Road Elementary School	EXTERIOR	Entrance to Building	Building Entrance-Door	1	The maneuvering clearance at the accessible door is not level and clear.	Exterior Door 2	ADA
78866	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk from the Southwest corner of the school to Exterior Door 4	ADA
78867	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Exterior Door 3, 4 and 8	ADA
78871	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Exterior Door 8 to the main sidewalk	ADA
78873	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	A level turning space is not provided at a turn in the accessible route.	Near Exterior Door 8	ADA
78878	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a running slope in excess of 1:12 (8.33%) and/or cross slope in excess of 1:48 (2.08%).	Ramp R-1	ADA
78879	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp does not have a level landing at the top and/or bottom of each run.	Ramp R-1	ADA
78880	Jackson Road Elementary School	EXTERIOR	Entrance to Building	Building Entrance-Door	1	The maneuvering clearance at the accessible door is not level and clear.	Exterior Door 9	ADA
78881	Jackson Road Elementary School	EXTERIOR	Entrance to Building	Building Entrance-Door	1	The maneuvering clearance at the accessible door is not level and clear.	Exterior Door 10	ADA
78882	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Next to Exterior Door 10	ADA
78887	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk South of the Gym	ADA
78888	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk West of Gym	ADA
78898	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk North side of Gym	ADA
78900	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a running slope in excess of 1:12 (8.33%) and/or cross slope in excess of 1:48 (2.08%).	Ramp R-3	ADA
78901	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp does not have a level landing at the top and/or bottom of each run.	Ramp R-2	ADA
78903	Jackson Road Elementary School	EXTERIOR	Entrance to Building	Building Entrance-Door	1	The maneuvering clearance at the accessible door is not level and clear.	Exterior Door 12	ADA
78908	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Near Exterior Door 12	ADA
78910	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Ramp R-3	ADA
78911	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a rise greater than 6"; however, handrails are not provided.	Ramp R-4	ADA
78912	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp does not have a level landing at the top and/or bottom of each run.	Ramp R-4	ADA
78919	Jackson Road Elementary School	EXTERIOR	Entrance to Building	Building Entrance-Door	1	The maneuvering clearance at the accessible door is not level and clear.	Exterior Door 16	ADA
78926	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a rise greater than 6"; however, handrails are not provided.	Ramp R-5	ADA
78928	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp does not have a level landing at the top and/or bottom of each run.	Ramp R-6	ADA
78931	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	A compliant accessible route is not provided from the public access to the amenity.	Picnic tables near Exterior Door 17	ADA
78934	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	A compliant accessible route is not provided from the public access to the amenity.	Baseball Fields	ADA
78942	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a rise greater than 6"; however, handrails are not provided.	Ramp R-8	ADA
78946	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk next to Playground #2	ADA



Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
78950	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Loading/Unloading Zone	1	The loading/unloading zone is not 96" wide by 20' long with vertical clearance of 114".	Student Dropoff (Car)	ADA
78952	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk next to Car Circle.	ADA
78955	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk East of Exterior Door 25	ADA
78956	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Curb Ramp	1	The curb ramp does not meet the slope requirements.	Curb Ramp CR-1	ADA
78957	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Curb Ramp	1	The slope of the curb ramp flares is greater than 1:10 (10%).	Curb Ramp CR-1	ADA
78958	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a running slope in excess of 1:12 (8.33%) and/or cross slope in excess of 1:48 (2.08%).	Ramp R-10	ADA
78959	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a rise greater than 6"; however, handrails are not provided.	Ramp R-10	ADA
78960	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a running slope in excess of 1:12 (8.33%) and/or cross slope in excess of 1:48 (2.08%).	Emergency Vehicle Pass Thru	ADA
78961	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalk from Emergency Vehicle Cross thru to Exterior Door 1	ADA
78962	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Curb Ramp	1	The curb ramp does not meet the slope requirements.	Curb Ramp CR-2	ADA
78963	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Van	1	The parking space slope is greater than 1:50 (2%).	Accessible Parking Space P5-A	ADA
78964	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Van	1	MARYLAND: A "Van" space is not provided.	Parking Lot 2	State of Maryland
78965	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Van	1	MARYLAND: The van access aisle is less than 96" wide.	Parking Lot 2	State of Maryland
78974	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The bus stop boarding and alighting area is not compliant.	Bus Drop Off	ADA
78966	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Van	1	MARYLAND: Signage indicating "No Parking in Access Aisle" at van access aisle is not provided.	Parking Lot 2	State of Maryland
78967	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Car	1	The slope of the parking space is greater than 1:50 (2%).	Accessible Parking Space P6-A	ADA
78968	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Van	1	The parking space slope is greater than 1:50 (2%).	Accessible Parking Space P6-B	ADA
78969	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Van	1	The access aisle has a slope more than 1:50 (2%).	Accessible Parking Space P6-B Access Aisle	ADA
78970	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Van	1	Compliant signage is not provided at the van space.	Accessible Parking Space P6-B	ADA
78971	Jackson Road Elementary School	EXTERIOR	Accessible Parking	Parking Space-Van	1	MARYLAND: Signage indicating "No Parking in Access Aisle" at van access aisle is not provided.	Accessible Parking Space P6-B	State of Maryland
78972	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Curb Ramp	1	The curb ramp does not meet the slope requirements.	Curb Ramp CR-3	ADA
78973	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Curb Ramp	1	A landing at the top of the curb ramp is not present.	Curb Ramp CR-3	ADA
78634	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Restroom RR-149	ADA
78735	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Restroom RR-133	ADA
78389	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Restroom RR-2, RR-11	ADA
78750	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The space between two doors in a series is less than 48" clear with doors open 90 degrees.	Restroom RR- 8	ADA
78751	Jackson Road Elementary School	INTERIOR	Common Areas	Interior Doors	1	The door has less than 32" clear width.	Restroom RR-8	ADA
78752	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Handrails are not provided on the stairs.	Stairs ST-5	State of Massachusetts
78753	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Steps do not have uniform and compliant riser heights and/or tread depths.	Stairs ST-5	ADA

Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
78754	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	The underside of the nosings are abrupt, not curved or beveled.	Stair ST-5	ADA
78755	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Handrails are not provided on the stairs.	Stair ST-6	State of Massachusetts
78756	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Steps do not have uniform and compliant riser heights and/or tread depths.	Stairs ST-6	ADA
78757	Jackson Road Elementary School	INTERIOR	Common Areas	Platform Lift	1	The platform lift requires a key for operation.	Platform Lift PL-1	ADA
78758	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Platform Lift PL-1	ADA
78759	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Platform Lift PL-1	ADA
78530	Jackson Road Elementary School	INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Drinking Fountain DF-2, DF-4, DF-6, DF-7, DF-8	ADA
78762	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Corridor to Rooms 209, 209-A, 209-B	ADA
78763	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Room 209B	ADA
78764	Jackson Road Elementary School	INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Restroom RR-213, RR-215	ADA
78765	Jackson Road Elementary School	INTERIOR	Exterior Access Route	Basketball Court	1	An accessible route does not directly connect each side of the court outside the play lines.	Gym	ADA
78846	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Handrail extensions are not compliant.	Stair ST-3	ADA
78538	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Interior Doors with Door Closer.	ADA
78539	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	1	The opening force of the accessible, hinged, non-fire door is more than 5 pounds.	Interior Doors with Door Closers	ADA
78847	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Steps do not have uniform and compliant riser heights and/or tread depths.	Stair ST-3	ADA
78848	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Steps do not have uniform and compliant riser heights and/or tread depths.	Stair ST-4	ADA
78850	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Handrail extensions are not compliant.	Stair ST-4	ADA
78853	Jackson Road Elementary School	INTERIOR	Interior Access Route	Vertical Clearance	1	Objects along the interior accessible route suspend from the ceilings lower than 80" AFF.	Stair ST-4	ADA
78859	Jackson Road Elementary School	INTERIOR	Interior Access Route	Stairs	1	Steps do not have uniform and compliant riser heights and/or tread depths.	Stair ST-5	ADA
78894	Jackson Road Elementary School	EXTERIOR	Entrance to Building	Building Entrance-Door	2	The bottom of the entry door vision light is higher than 43" maximum.	Mobile Classroom ML1014	ADA
78935	Jackson Road Elementary School	EXTERIOR	Picnic Area	Picnic Table	2	The picnic table does not allow a clear space for forward wheelchair approach with knee and toe clearance.	Picnic Tables near hard playing surface	ADA
78944	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Gate	2	The swinging gate does not have a smooth surface within 10" of the ground measured vertically on the push side extending the full width of the gate.	Entrance to Playground 2	ADA
78954	Jackson Road Elementary School	EXTERIOR	Exterior Access Route	Gate	2	The swinging gate does not have a smooth surface within 10" of the ground measured vertically on the push side extending the full width of the gate.	Playground #3	ADA
78975	Jackson Road Elementary School	EXTERIOR	Playground	Transfer System	2	The side of the transfer platform used for transfer is obstructed.	Playground #1	ADA
78976	Jackson Road Elementary School	EXTERIOR	Playground	Ground Surface-Fibar	2	The ground surface has not been inspected and maintained regularly.	Playgrounds 1, 2, 3	ADA
78269	Jackson Road Elementary School	INTERIOR	Kitchen	Sink	2	Exposed pipes lack insulation and/or sharp or abrasive surfaces are present under the sink.	Classrooms 100, 104, 107, 135, 152	ADA

Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
78626	Jackson Road Elementary School	INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed forward reach motion are higher than 48" maximum or lower than 15" minimum height above finish floor.	Room 120	ADA
78631	Jackson Road Elementary School	INTERIOR	Kitchen	Sink	2	Exposed pipes lack insulation and/or sharp or abrasive surfaces are present under the sink.	Classrooms 141, 143	ADA
78633	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	2	The surface of the door within 10" of the finish floor or ground for the full width of the door on the push side is not smooth.	Hallway Fire Doors	ADA
78740	Jackson Road Elementary School	INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Room 124	ADA
78401	Jackson Road Elementary School	INTERIOR	Interior Access Route	Reach Range	2	Items that require a forward reach motion require more than 48" height reach.	Fire Pull Stations	ADA
78515	Jackson Road Elementary School	INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Room 103D	ADA
78516	Jackson Road Elementary School	INTERIOR	Interior Access Route	Reach Range	2	Items that require a forward reach motion require more than 48" height reach.	Room 103D	ADA
78518	Jackson Road Elementary School	INTERIOR	Interior Access Route	Signage	2	The provided signage does not have color contrast and a non-glare finish.	All Interior Room Identification Signs except Restrooms	ADA
78519	Jackson Road Elementary School	INTERIOR	Interior Access Route	Sink	2	The sink used primarily by children aged 6 to 12 has over 31" max. ht. rim. OR does not have knee clearance of 24" min. above finished floor (parallel approach permitted for children aged 5 and younger).	Restroom in Classroom 175	ADA
78526	Jackson Road Elementary School	INTERIOR	Interior Access Route	Sink	2	The sink used primarily by children aged 6 to 12 has over 31" max. ht. rim. OR does not have knee clearance of 24" min. above finished floor (parallel approach permitted for children aged 5 and younger).	Restroom in Classroom 174	ADA
78528	Jackson Road Elementary School	INTERIOR	Common Areas	Vending Machine	2	The vending machines have operable parts which are not within reach range.	Room 163	ADA
78531	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	2	The surface of the door within 10" of the finish floor or ground for the full width of the door on the push side is not smooth.	Interior Doors with Door Closers	ADA
78545	Jackson Road Elementary School	INTERIOR	Interior Access Route	Door	2	The surface of the door within 10" of the finish floor or ground for the full width of the door on the push side is not smooth.	Room 115, 135	ADA
78625	Jackson Road Elementary School	INTERIOR	Common Areas	Dining And Work Surface	2	The dining or work surface does not have a minimum 28" and maximum 34" height with knee and toe clearance.	Room 118 - Media Center	ADA
78250	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The centerline of the toilet in the wheelchair stall is not 16" minimum to 18" maximum from the sidewall.	Restroom in Classrooms 106, 108, 109, 110, 114	ADA
78254	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The toilet paper dispenser is not at a compliant location.	Restroom in Classrooms 100, 103, 104, 106, 108, 109, 110, 114, 174	ADA
78258	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The side grab bar at the water closet is not compliant.	Restroom in Classrooms 108, 110, 114	ADA
78260	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a single/user or unisex restroom does not have the required clearance.	Restroom in Classrooms 106, 108, 110, 114	ADA
78264	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Restrooms in Classrooms 100, 104, 105, 106, 108, 109, 110, 114	ADA
78265	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The rear grab bar at the water closet is not compliant.	Restroom in Classrooms 106, 108, 110	ADA
78266	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The space between the grab bar and projecting objects above the grab bar is less than 12" minimum.	Restroom in Classrooms 106, 110	ADA
78636	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	Restrooms	ADA
78640	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Urinal	3	The clear floor space at the urinal is less than minimum 30" by minimum 48".	Restroom RR-149, RR-203	ADA

Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
78641	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The toilet paper dispenser is not at a compliant location.	Restrooms RR-139, RR-149, RR-151, RR-203, RR-205, RR-213, RR-215	ADA
78643	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Coat Hook	3	The coat hook is not within an allowable reach range.	Restroom RR-149, RR-151, RR-213, RR-215	ADA
78644	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	The wheelchair stall with a floor mounted water closet, in a multi-stall restroom, is less than 60" wide and 59" deep.	Restroom RR-149, RR-203, RR-205, RR-213	ADA
78646	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Door	3	The threshold at the accessible door is greater than 1/2" in height.	Restrooms RR-129, RR-133, RR-149, RR-151	ADA
78331	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The grab bars at the water closet are not compliant.	Restroom inside Classroom 109	ADA
78335	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Door	3	The threshold at the accessible door is greater than 1/2" in height.	Restroom in Classroom 109	ADA
78339	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Restroom RR-111, RR-112	ADA
78341	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Door	3	The wheelchair stall door is not self closing.	Restroom RR-111	ADA
78342	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	The wheelchair stall door is not compliant.	Restroom R-111, RR-112, RR-376, RR-378	ADA
78344	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Restrooms RR-111, RR-112, RR-376, RR-378	ADA
78345	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The toilet paper dispenser is not at a compliant location.	Restrooms RR-111, RR-112, RR-378	ADA
78346	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Door	3	The threshold at the accessible door is greater than 1/2" in height.	Restrooms RR-111, RR-112	ADA
78367	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The centerline of the toilet in the wheelchair stall is not 16" minimum to 18" maximum from the sidewall.	Restroom RR-112	ADA
78368	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	The rear grab bar in the wheelchair stall is not compliant.	Restroom RR-112	ADA
78378	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The toilet paper dispenser is not at a compliant location.	Restroom RR-1, RR-2, RR-4, RR-5, RR-6, RR-7, RR-8, RR-9, RR-11, RR-12	ADA
78654	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Door	3	The threshold at the accessible door is greater than 1/2" in height.	Restroom RR1, RR-2, RR-3, RR-4, RR-5, RR-6, RR-7	ADA
78736	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Restrooms RR-129, RR-133, RR-203, RR-205, RR-213, RR-215	ADA
78737	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The centerline of the toilet in the wheelchair stall is not 16" minimum to 18" maximum from the sidewall.	Restroom RR-129, RR-213, RR-215	ADA
78738	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom	3	Dispenser and/or dispenser controls are not within an allowable reach range.	Restrooms RR-6, RR-7	ADA
78739	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The rear grab bar at the water closet is not compliant.	Restroom RR-7	ADA
78741	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Restroom in Room 124 Health	ADA
78742	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom	3	Dispenser and/or dispenser controls are not within an allowable reach range.	Restroom in Room 124 Health	ADA
78743	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The centerline of the toilet in the wheelchair stall is not 16" minimum to 18" maximum from the sidewall.	Restrooms in Room 124 Health	ADA
78744	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The side grab bar at the water closet is not compliant.	Restroom in Room 124 - Health	ADA
78745	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The rear grab bar at the water closet is not compliant.	Restroom in Room 124 - Health	ADA
78746	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a single/user or unisex restroom does not have the required clearance.	Restroom in Room 124 - Health	ADA



Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
78383	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a single/user or unisex restroom does not have the required clearance.	Restrooms RR-1, RR-2, RR-4, RR-5, RR-8, RR-9, RR-10, RR-11, RR-12	ADA
78387	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Coat Hook	3	The coat hook is not within an allowable reach range.	Restrooms RR-1, RR-2, RR-4, RR-5, RR-6, RR-7, RR-11, RR-12	ADA
78393	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The centerline of the toilet in the wheelchair stall is not 16" minimum to 18" maximum from the sidewall.	Restrooms RR-1, RR-2, RR-4, RR-5, RR-9, RR-11, RR-12, RR-13	ADA
78395	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The side grab bar at the water closet is not compliant.	Restroom RR-2	ADA
78396	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The rear grab bar at the water closet is not compliant.	Restroom RR-2, RR-4, RR-8, RR-9	ADA
78398	Jackson Road Elementary School	INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Egress Doors, Stairways	ADA
78512	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a single/user or unisex restroom does not have the required clearance.	Restrooms in Classrooms 100, 104, 105	ADA
78747	Jackson Road Elementary School	INTERIOR	Common Areas	Assembly Area	3	The assistive listening device is not compliant or is not provided.	All Purpose Room	ADA
78748	Jackson Road Elementary School	INTERIOR	Employee Work Areas	Locker Rooms-Bench	3	The locker room does not have a compliant bench.	Restroom RR-8, RR-9, RR-10	ADA
78749	Jackson Road Elementary School	INTERIOR	Employee Work Areas	Locker Rooms	3	The locker room does not have accessible lockers.	Restroom RR-8, RR-9, RR-10	ADA
78760	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	Restroom RR-9	ADA
78761	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The side grab bar at the water closet is not compliant.	Restroom RR-9	ADA
78517	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Restroom in Classroom 106	ADA
78521	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The grab bars at the water closet are not compliant.	Restroom in Classroom 175	ADA
78525	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The grab bars at the water closet are not compliant.	Restroom in Classroom 175	ADA
78527	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The centerline of the toilet in the wheelchair stall is not 16" minimum to 18" maximum from the sidewall.	Restroom in Classroom 174	ADA
78767	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The space between the grab bar and projecting objects above the grab bar is less than 12" minimum.	Restroom RR-10, RR-11, RR-12	ADA
78768	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	The curb is more than 1/2" high.	Restroom RR-9, RR-10	ADA
78769	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	A transfer seat is provided but is not compliant.	Restrooms RR-9, RR-10	ADA
78838	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	The lavatory does not have the required knee clearance.	Restroom RR-376, RR-378	ADA
78840	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The centerline of the toilet in the wheelchair stall is not 16" minimum to 18" maximum from the sidewall.	Restroom RR-376	ADA
78843	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	The rear grab bar in the wheelchair stall is not compliant.	Restroom RR-376, RR-378	ADA
78845	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a single/user or unisex restroom does not have the required clearance.	RR-13	ADA
78532	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	Restrooms, RR-133, RR-176	ADA
78533	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	The wheelchair stall door is not compliant.	Restrooms RR-129, RR-133, RR-149, RR-151, RR-176, RR-203, RR-205, RR-213, RR215	ADA
78534	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Door	3	The wheelchair stall door is not self closing.	Restrooms RR-149, RR-176, RR-203	ADA
78535	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Restrooms RR-129, RR-133, RR-149, RR-151, RR-176, RR-178 RR-203, RR-205, RR-213, RR-215	ADA





Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
78536	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The grab bars at the water closet are not compliant.	Restrooms RR-176, RR-178	ADA
78537	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	The lavatory does not have the required knee clearance.	Restrooms RR-176, RR-178	ADA
78540	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Restroom RR-3, RR-6, RR-7, RR-8, RR-9, RR-10, RR-11, RR-12, RR-13	ADA
78541	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	The lavatory is mounted higher than 34" to the higher of the rim or counter.	Restrooms RR-3, RR-7	ADA
78542	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The grab bars at the water closet are not compliant.	Restroom RR-3	ADA
78543	Jackson Road Elementary School	INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a single/user or unisex restroom does not have the required clearance.	Restroom RR-3	ADA
78857	Jackson Road Elementary School	INTERIOR	Interior Access Route	Elevator	3	A tactile, raised star minimum 2" high is not provided to the left of the floor designation on both jambs at the main elevator entry level.	Elevator EV-2	ADA
78245	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Classrooms 100, 104, 105, 107, 108, 110, 114, 145, 152, 153, 154, 155, 202, 204, 360, 363, 364, 366, 368, 369, 371, 372, 374, 375	ADA
78247	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The spout of the lower level drinking fountain is located more than 5" from the front edge of the fountain.	Classrooms 100, 104, 105, 107, 108, 110, 114, 145, 152, 153, 154, 155, 202, 204, 360, 363, 364, 366, 368, 369, 371, 372, 374, 375	ADA
78326	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Classrooms 109, 113, 135, 139, 164, 166, 168, 169, 171, 172, 174, 175	ADA
78628	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Classrooms 143, 147, 150, 206, 211	ADA
78629	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The spout of the lower level drinking fountain is located more than 5" from the front edge of the fountain.	Classrooms 143, 147, 150, 206, 211	ADA
78327	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The spout of the lower level drinking fountain is located more than 5" from the front edge of the fountain.	Classrooms 109, 113, 135, 139, 164, 166, 168, 169, 171, 172, 174, 175	ADA
78369	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Drinking Fountain DF-1, DF-3, DF-7	ADA
78513	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Room 103D	ADA
78514	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The spout of the lower level drinking fountain is located more than 5" from the front edge of the fountain.	Room 103D	ADA
78522	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Classroom 175	ADA
78523	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The spout of the lower level drinking fountain is located more than 5" from the front edge of the fountain.	Classrooms 175	ADA
78529	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The spout of the standing height drinking fountain is not between 38" minimum and 43" maximum.	Drinking Fountain DF-2, DF-4, DF-8	ADA
78770	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Drinking Fountain DF-6	ADA

Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
78546	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Room 116, 124	ADA
78547	Jackson Road Elementary School	INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	The spout of the lower level drinking fountain is located more than 5" from the front edge of the fountain.	Room 116, 124	ADA