



# ADA TITLE II ASSESSMENT

Prepared for:

**Montgomery County Public Schools**  
45 West Gude Drive, Suite 4100  
Rockville, Maryland 20850



## ADA TITLE II ASSESSMENT

Poolesville High School  
17501 Willard Road  
Poolesville, Maryland 20837

### PREPARED BY:

EMG  
10461 Mill Run Circle, Suite 1100  
Owings Mills, Maryland 21117  
800.733.0660  
[www.EMGcorp.com](http://www.EMGcorp.com)

### EMG CONTACT:

Michael Nelson  
Program Manager  
800.733.0660 x6244  
[mnelson@emgcorp.com](mailto:mnelson@emgcorp.com)

**EMG Project Number:**  
123821.17R000-141.303

**Date of Report:**  
October 28, 2019

**On Site Date:**  
May 21-23 and July 5, 2018



# 1 Accessibility

Generally, Title II of the Americans with Disabilities Act (ADA) prohibits discrimination by entities to access and use of the government entity’s programs, services, and facilities on the basis of disability. Regardless of their age, these areas and facilities must be maintained and operated to comply with the Americans with Disabilities Act Accessibility Guidelines (ADAAG), and applicable state and local accessibility regulations.

Buildings completed and occupied after January 26, 1992 are required to comply fully with ADAAG. Existing facilities constructed prior to this date are held to the lesser standard of complying to the extent allowed by structural feasibility and the financial resources available, or a reasonable accommodation must be made. The ADA guidelines were clarified and amended in 2010 based on a clarification by the Department of Justice known as the “2011 Site Construction Tolerances Addendum to the 2010 ADA Standards for Accessible Design.” The aforementioned document defines the acceptable and allowed construction tolerances above or below the requirements established in the 2010 ADA Standards for barriers related to:

- Accessible Parking
- Pedestrian Path of Travel
- Building Entrances
- Interior Spaces

The scope of the ADA Assessment, as defined in the scope of work, is limited to exterior and interior areas covered by the ADA.

Based on the onsite review, EMG found that barriers to accessibility exist at Poolesville High School. The observed elements were analyzed using the 2010 ADA Standards for Accessible Design and state accessibility codes.

## 1.1 Accessibility Summary Table

Based on the onsite review, EMG found that barriers to accessibility exist at Poolesville High School. The observed elements were analyzed using the 2010 ADA Standards for Accessible Design and state accessibility codes.

EMG’s assessment of the subject property identified the following areas of concern:

**POOLESVILLE HIGH SCHOOL - TITLE II ADA COMPLIANCE ASSESSMENT - ACCESSIBILITY SUMMARY**

Facility/Building	Priority 1 Items	Priority 2 Items	Priority 3 Items	Priority 4 Items	Priority 5 Items	Total Items
Poolesville High School	64	20	44	4	3	135
Grand Total	64	20	44	4	3	135

Order of magnitude costs to address those elements are described individually in Appendix A.

## 1.2 Barrier Summary Table

The following table summarizes the barriers that were identified. The costs provided are order of magnitude estimates. Costs will vary depending upon the location and volume of work performed. Individual observation details may be found in Appendix A.



Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
111244	Poolesville High School	Building Exterior	Exterior Access Route	Stairs	1	Handrails are not provided.	Stair ST2 and ST3	ADA
111247	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Car	1	The parking space is less than 96" wide.	Parking Stall P5	ADA
111248	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Car	1	The access aisle is less than 60" wide.	Access Aisle between P5 and P6	ADA
111249	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Car	1	The parking space is less than 96" wide.	Parking Stall P6	ADA
111250	Poolesville High School	Building Exterior	Exterior Access Route	Stairs	1	Handrails are not compliant.	Stair ST4	ADA
111251	Poolesville High School	Building Exterior	Interior Access Route	Ramp	1	The ramp run rises 6" or greater but has no handrails.	Ramp R1	ADA
111253	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Door 28	ADA
111254	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The accessible route has greater than 1:20 (5%) running slope and 1:50 (2%) cross slope.	Stadium seating	ADA
111256	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	A compliant accessible route is not provided from the property line to the site facilities.	Baseball Field	ADA
111224	Poolesville High School	Building Exterior	Exterior Access Route	Stairs	1	Handrails are not provided.	Stair ST1	ADA
111225	Poolesville High School	Building Exterior	Exterior Access Route	Stairs	1	Handrail extensions are not compliant.	Stair ST1	ADA
111226	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Van Loading/Unloading Zone	1	MARYLAND: Signage indicating "No Parking in Access Aisle" at van access aisle is not provided.	Between Parking Stall P1 and P2, and P3 and P4	State of Maryland
111227	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The access aisle is not marked.	Loading/Unloading Zone	ADA
111228	Poolesville High School	Building Exterior	Exterior Access Route	Curb Ramp	1	The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Curb Ramp CR1	ADA
111231	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	A compliant accessible route is not provided from accessible parking to the public facility entrance.	From CR2 to building entrance	ADA
111232	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Sidewalk next to CR2	ADA
111233	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Car	1	MARYLAND: Compliant signage is not provided at the space.	Parking Stalls P7 and P8, and Stalls P3 and P4	State of Maryland
111234	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Sidewalks from CR3	ADA
111235	Poolesville High School	Building Exterior	Exterior Access Route	Curb Ramp	1	The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Curb Ramp CR4	ADA
111259	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	A compliant accessible route is not provided from the property line to the site facilities.	Softball Field	ADA
111261	Poolesville High School	Building Exterior	Exterior Access Route	Stairs	1	Handrails are not provided.	Stair ST5	ADA
111262	Poolesville High School	Building Exterior	Exterior Access Route	Ramp	1	The ramp is required but not provided.	Tennis Courts Access	ADA
111263	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	Accessible Route between tennis courts and exterior basketball courts	ADA
111264	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible route from parking to Stadium	ADA
111265	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The accessible route has running slopes greater than 1:20 (5%).	Accessible route adjacent exterior basketball courts	ADA
111266	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Van	1	A van space is not provided.	Parking Lot A	ADA
111267	Poolesville High School	Building Exterior	Accessible Parking	Parking Spaces-General	1	The minimum number of accessible parking spaces is not provided.	Parking Lot B	ADA
112334	Poolesville High School	Building Exterior	Exterior Access Route	Ramp	1	The ramp has a rise greater than 6"; however, handrails are not provided.	Tennis Court Access	ADA
112397	Poolesville High School	Building Exterior	Exterior Access Route	Curb Ramp	1	A curb ramp is not provided where the accessible route crosses a curb.	Unloading/Loading Zone by Stair ST1	ADA
112398	Poolesville High School	Building Exterior	Exterior Access Route	Ramp	1	The ramp does not have a level landing at the top and/or bottom of each run.	Ramp R4	ADA
112399	Poolesville High School	Building Exterior	Exterior Access Route	Ramp	1	The handrails are not compliant.	Ramp R4	ADA
111236	Poolesville High School	Building Exterior	Exterior Access Route	Ramp	1	The ramp is required but not provided.	Ramp R4	ADA
111237	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	CR4 to CR3	ADA
111238	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Van	1	The access aisle has a slope more than 1:50 (2%).	Access Aisle between Parking Stalls P3 and P4	ADA



Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
111239	Poolesville High School	Building Exterior	Exterior Access Route	Curb Ramp	1	The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Curb Ramp CR3	ADA
111240	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Van	1	The parking space slope is greater than 1:50 (2%).	Parking Stall P3	ADA
111241	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The accessible route has cross slopes greater than 1:50 (2%).	From CR3 to up past parking stall P8	ADA
111242	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	The accessible route has running slopes greater than 1:20 (5%).	Accessible route between ST2 and ST3	ADA
111243	Poolesville High School	Building Exterior	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Accessible route between ST2 and ST3	ADA
104114	Poolesville High School	Building Interior	Interior Access Route	Door	1	The space between two doors in a series is less than 48" clear with doors open 90 degrees.	Double-Leaf Doors (DR34)	ADA
104169	Poolesville High School	Building Interior	Interior Access Route	Door	1	The hardware at the accessible door (including sliding doors - both sides) requires tight grasping, pinching or twisting of the wrist to operate OR is mounted below 34" or above 48".	Classrooms & Student Spaces	ADA
104181	Poolesville High School	Building Interior	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Building Services Door	ADA
104251	Poolesville High School	Building Interior	Basketball Court	Sport Court	1	An accessible route does not directly connect each side of the court outside of play lines.	Aux. Gymnasium	ADA
104286	Poolesville High School	Building Interior	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Student & Staff Spaces: Guidance Office, Financial Office, Main Office - Corridor (2)	ADA
104290	Poolesville High School	Building Interior	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Classrooms & Student Spaces#: 8, 9, 14, 21, 26, 29, 30, 43, 49	ADA
104306	Poolesville High School	Building Interior	Interior Access Route	Stairs	1	Handrails are not provided.	Interior Stair: Stair 6 (STR6)	ADA
105627	Poolesville High School	Building Interior	Interior Access Route	Controls And Dispensers	1	The height of controls throughout the common area are not compliant.	Student Spaces & Classrooms	ADA
105628	Poolesville High School	Building Interior	Interior Access Route	Controls And Dispensers	1	The height of controls throughout the common area are not compliant.	Staff Offices & Spaces	ADA
105630	Poolesville High School	Building Interior	Interior Access Route	Stairs	1	Handrails are not compliant.	Interior Stairs: Stair 3, Stair 4 (STR3 & STR4)	ADA
106271	Poolesville High School	Building Interior	Interior Access Route	Ramp	1	A ramp is required but not provided.	Stair 9 (STR9)	ADA
106280	Poolesville High School	Building Interior	Interior Access Route	Platform Lift	1	A platform lift is required but not provided.	Classrooms #63 & 64	ADA
106281	Poolesville High School	Building Interior	Interior Access Route	Platform Lift	1	The platform lift is not compliant.	Classroom #23	ADA
106344	Poolesville High School	Building Interior	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Auditorium Entry Corridor & Main Entry Corridor	ADA
106532	Poolesville High School	Building Interior	Interior Access Route	Stairs	1	Handrail extensions are not compliant.	Interior Stair 5 (STR5)	ADA
106562	Poolesville High School	Building Interior	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Business Admin. Office	ADA
106567	Poolesville High School	Building Interior	Interior Access Route	Door	1	The door has less than 32" clear width.	Business Admin. Office	ADA
106574	Poolesville High School	Building Interior	Interior Access Route	Stairs	1	Handrail extensions are not compliant.	Interior Stair: Stair 7 (STR7)	ADA
107268	Poolesville High School	Building Interior	Interior Access Route	Ramp	1	The ramp run rises 6" or greater but has no handrails.	Ramp 3 (R3)	ADA
107364	Poolesville High School	Building Interior	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Corridor near Door 8 (DR8)	ADA
107368	Poolesville High School	Building Interior	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Main Gymnasium Entry Corridor - Door 41 (DR#41)	ADA
107399	Poolesville High School	Building Interior	Interior Access Route	Stairs	1	Handrail extensions are not compliant.	Auditorium Stairs - Stair 3 & Stair 4 (STR3) (STR4)	ADA
104275	Poolesville High School	Building Interior	Interior Access Route	Door	1	The hardware at the accessible door (including sliding doors - both sides) requires tight grasping, pinching or twisting of the wrist to operate OR is mounted below 34" or above 48".	Staff Rooms & Spaces	ADA
109348	Poolesville High School	Building Interior	Interior Access Route	Ramp	1	The ramp run rises 6" or greater but has no handrails.	Stair 9 (STR9)	ADA
109355	Poolesville High School	Building Interior	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Drinking Fountains: 2, 6	ADA
111252	Poolesville High School	Building Exterior	Picnic Area	Picnic Table	2	The picnic table does not allow a clear space for forward wheelchair approach with knee and toe clearance.	Picnic Area	ADA
111255	Poolesville High School	Building Exterior	Baseball/Softball Field	Player Seating	2	A wheelchair space is not provided at each team bench area at the ball field.	Bseball Field	ADA
111257	Poolesville High School	Building Exterior	Baseball/Softball Field	Bleacher Seating	2	The required number of wheelchair spaces is not provided at the bleacher seating for the ball field.	Baseball Field	ADA



Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
111258	Pooleville High School	Building Exterior	Baseball/Softball Field	Bleacher Seating	2	The required number of wheelchair spaces is not provided at the bleacher seating for the ball field.	Softball Field	ADA
111230	Pooleville High School	Building Exterior	Picnic Area	Picnic Table	2	The picnic table does not allow a clear space for forward wheelchair approach with knee and toe clearance.	Picnic Tables (Front of School)	ADA
111260	Pooleville High School	Building Exterior	Baseball/Softball Field	Player Seating	2	A wheelchair space is not provided at each team bench area at the ball field.	Softball Field	ADA
112400	Pooleville High School	Building Exterior	Picnic Area	Picnic Table	2	Clear ground space around the picnic table is less than 36" width.	Picnic Tables: Front of School and around gymnasium	ABA
112401	Pooleville High School	Building Exterior	Common Areas	Assembly Area	2	An assistive listening system is required, but not provided.	Football Stadium	ADA
104161	Pooleville High School	Building Interior	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Teacher & Resource Room (2), Main Office Workroom	ADA
104244	Pooleville High School	Building Interior	Basketball Court	Player Seating	2	A wheelchair space is not provided at the seating for the basketball courts.	Main Gymnasium & Aux. Gymnasium	ADA
104256	Pooleville High School	Building Interior	Basketball Court	Player Seating	2	The wheelchair space is not the minimum required dimensions at the team or player seating for the basketball courts.	Main Gymnasium & Aux. Gymnasium	ADA
104304	Pooleville High School	Building Interior	Interior Access Route	Signage	2	Means of egress signage does not have tactile lettering.	Interior Accessible Routes	ADA
105609	Pooleville High School	Building Interior	Interior Access Route	Signage	2	The interior signage does not have compliant visual and tactile characters, with raised or indented characters or symbols.	Classrooms and Student Spaces	ADA
105611	Pooleville High School	Building Interior	Interior Access Route	Signage	2	The interior signage does not have compliant visual and tactile characters, with raised or indented characters or symbols.	Staff Rooms & Spaces	ADA
106342	Pooleville High School	Building Interior	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Health Office	ADA
106480	Pooleville High School	Building Interior	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Art Classroom Sinks	ADA
106533	Pooleville High School	Building Interior	Concession Stand	Service Counter	2	The service counter height is greater than 36" and/or the counter length is less than 36", where a parallel approach is present.	Auditorium Box Office	ADA
106583	Pooleville High School	Building Interior	Common Areas	Service Counter	2	The service counter does not have 36" wide section that is 36" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 30" wide section that is 36" maximum, with knee and toe clearance, that is oriented for a forward approach.	Media Center Service Counter	ADA
107104	Pooleville High School	Building Interior	Common Areas	Vending Machine	2	The vending machines have operable parts which are not within reach range.	Common Spaces & Corridors (Cafeteria, Near Door 11 (DR11) Entrance, Gymnasium Corridor)	ADA
107369	Pooleville High School	Building Interior	Restroom	Protruding Object	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	Restrooms: Student RR #: 8, 9	ADA
104112	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Door	3	The hardware at the accessible door requires tight grasping, pinching or twisting of the wrist to operate.	Restrooms: Staff RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	UFAS
104294	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Door	3	The door has less than 32" clear width	Restrooms: Student RR #: 2, 3, 10, 11, 12, 13	ADA
104295	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Door	3	The door has less than 32" clear width	Restrooms: Staff RR #: 1, 6, 7, 19, 21, 24, 25, 26	ADA
105629	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Coat Hook	3	The coat hook is not within an allowable reach range.	Restrooms: _____	ADA
106272	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	Restrooms: Student RR #: 2, 3, 4, 5, 8, 9, 10, 12, 13, 14, 15, 16, 18; Men's Dressing Room Restroom, Women's Dressing Room Restroom	ADA
106273	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	Restrooms: Staff RR #: 1, 6, 7, 19, 22, 24, 25, 26, 27, 28	ADA
106274	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Signage	3	The provided signage is not mounted at the latch side of the door or at a compliant height.	Restrooms: Student RR #: 2, 3, 4, 5, 8, 9, 10, 11, 12, 13, 14, 15, 16, 18, 20	ADA
106275	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Signage	3	The provided signage is not mounted at the latch side of the door or at a compliant height.	Restrooms: Staff RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	ADA
106276	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Restrooms: Staff RR #: 27, 28	ADA
106277	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Restrooms: Student RR#: 2, 3, 4, 5, 13, 20	ADA
106278	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Restrooms: Student RR #: 10, 11, 14, 15, 20	ADA
106279	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a wheelchair stall in a multi-stall restroom does not have the required clearance.	Restrooms: Student RR #: 2, 3, 4, 5, 8, 9, 10, 11, 12, 13, 14, 15	ADA
106283	Pooleville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a single/user or unisex restroom does not have the required clearance.	Restrooms: Staff RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28, 29, 32	ADA



Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
106437	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a single/user or unisex restroom does not have the required clearance.	Restroom: Student RR#: 20	ADA
106443	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The toilet paper dispenser is not at a compliant location.	Restrooms: Staff RR #: 1, 24, 25, 26, 27, 28	ADA
106445	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Restrooms: Staff RR#: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	ADA
106449	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Urinal	3	The clear floor space at the urinal is less than minimum 30" by minimum 48".	Restrooms: Student RR #: 2, 8, 10	ADA
106461	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The side grab bar at the water closet is not compliant.	Restrooms: Staff RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	ADA
106463	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The rear grab bar at the water closet is not compliant.	Restrooms: Staff RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	ADA
106469	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Restrooms: Staff RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	ADA
106521	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom	3	The height of controls are not compliant.	Restrooms: Staff RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	ADA
106571	Poolesville High School	Building Interior	Locker and Dressing Rooms	Locker and Dressing Rooms	3	The locker room does not have a compliant bench.	Girls Locker Room & Boys Locker Room	ADA
106577	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The toilet paper dispenser is not at a compliant location.	Restrooms: Student RR #: 2, 3, 8, 9	ADA
106578	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom	3	The height of controls are not compliant.	Restrooms: Student RR #: 2, 3, 4, 5, 8, 9, 10, 11, 12, 13, 14, 15, 16, 18, 20	ADA
106589	Poolesville High School	Building Interior	Locker and Dressing Rooms	Locker and Dressing Rooms	3	The locker room does not have accessible lockers.	Boys Locker Room & Girls Locker Room	ADA
106591	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Restroom: Student RR #: 2, 3, 10, 11, 12, 13	ADA
106593	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	Grab bars are not compliant or are not provided in the transfer shower stall.	Men's & Women's P/E Office Restroom Showers (Staff RR#: 6, 7)	ADA
107273	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	The transfer shower is not exactly 36" by 36".	Men's P/E Office Shower (Staff RR# 6)	ADA
107275	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	The required clearance at the entry to the transfer stall is not provided.	Men's & Women's P/E Office Showers (RR#: 6, 7)	ADA
107361	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	The spray unit does not have a minimum 59" long hose.	Men's & Women's P/E Office Showers (RR#: 6, 7)	ADA
107362	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	A seat is not provided in the transfer shower stall.	Men's & Women's P/E Office Showers (RR#: 6, 7)	ADA
107363	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	The curb is more than 1/2" high.	Men's & Women's P/E Office Showers (RR#: 6, 7)	ADA
107366	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The rear grab bar at the water closet is not compliant.	Restrooms: Student RR #: 2, 3, 4, 5, 10, 11, 12, 13, 14, 15, 20	ADA
107367	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The side grab bar at the water closet is not compliant.	Restrooms: Student RR #: 2, 3, 4, 5, 10, 11, 12, 13, 14, 15	ADA
107370	Poolesville High School	Building Interior	Common Areas	Locker Rooms	3	The locker room does not have accessible lockers.	Men's & Women's P/E Office Locker Room (Restroom#: 6, 7)	ADA
107371	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Door	3	The hardware at the accessible door requires tight grasping, pinching or twisting of the wrist to operate.	Restrooms: Student RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	UFAS
107372	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Water Closet	3	The accessible dispensers are not at compliant heights.	Restrooms: Staff RR #: 1, 6, 7, 17, 19, 21, 22, 23, 24, 25, 26, 27, 28	ADA
107398	Poolesville High School	Building Interior	Restroom	Restroom/Bathroom-Toilet Stall	3	A wheelchair stall is not provided in a multi-user restroom.	Restrooms: Student RR #: 2, 3, 4, 5, 10, 11, 12, 13	ADA
104278	Poolesville High School	Building Interior	Employee Work Areas	Locker Rooms	3	The locker room does not have accessible lockers.	Building Services Staff Lockers	ADA
104282	Poolesville High School	Building Interior	Employee Work Areas	Locker Rooms	3	The locker room does not have accessible lockers.	Kitchen Staff Lockers	ADA
104284	Poolesville High School	Building Interior	Common Areas	Locker Rooms	3	The locker room does not have accessible lockers.	Corridor Student Lockers	ADA
107401	Poolesville High School	Building Interior	Common Areas	Assembly Area	3	Assembly areas do not provide companion spaces	Auditorium	ADA
107402	Poolesville High School	Building Interior	Common Areas	Assembly Area	3	Assembly areas do not provide wheelchair spaces.	Auditorium	ADA
109358	Poolesville High School	Building Interior	Common Areas	Assembly Area	3	Assembly areas do not provide compliant aisle seats.	Auditorium	ADA



Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA
104307	Poolesville High School	Building Interior	Interior Access Route	Drinking Fountain/Water Cooler	4	The controls at the accessible drinking fountain are not compliant.	Drinking Fountain (DF2, DF3, DF4, DF6)	ADA
105625	Poolesville High School	Building Interior	Site Furnishings	Drinking Fountain/Water Cooler	4	A clear space is not positioned at the drinking fountain for a forward approach and centered on the unit.	Drinking Fountains: DF1	ADA
106282	Poolesville High School	Building Interior	Interior Access Route	Drinking Fountain/Water Cooler	4	The minimum number of drinking fountains is not provided. If the minimum number is provided, two levels or a hi-lo are not provided. If more than 2 are provided, less than 50% are high or less than 50% are low.	Corridors	ADA
104283	Poolesville High School	Building Interior	Common Areas	Locker Rooms	4	The locker room does not have at least one of the shelves at 40" minimum and 48" maximum height.	Corridor Student Lockers	ADA
111229	Poolesville High School	Building Exterior	Exterior Access Route	Curb Ramp	5	A curb ramp is not provided where the accessible route crosses a curb.	Curb Ramp CR2	ADA
112329	Poolesville High School	Building Exterior	Accessible Parking	Parking Space-Van	5	MARYLAND: Signage indicating "No Parking in Access Aisle" at van access aisle is not provided.	Parking Lot C: Stalls P7 and P8	State of Maryland
109630	Poolesville High School	Building Interior	Employee Work Areas	Locker Rooms-Bench	5	The locker room does not have a compliant bench.	Building Services & Kitchen Staff Locker Rooms	ADA

