

Attachment E

Montgomery County Public Schools Lead in Drinking Water Post-Remediation Testing Report

Montgomery Knolls Elementary School
807 Daleview Drive
Silver Spring, MD 20901

Report Date: October 31st, 2023

LEAD IN DRINKING WATER POST-REMEDIATION SAMPLE RESULTS SUMMARY

One drinking water outlet was remediated at Montgomery Knolls Elementary School due to an initial first draw concentration that exceeded the Action Level of 5 parts per billion (ppb). Inspections Experts Inc. collected a post-remediation follow-up first draw sample which was submitted to a laboratory for lead in water analysis. The laboratory has been certified by the Maryland Department of the Environment (MDE) to analyze drinking water for lead.

The post-remediation follow-up first draw results are highlighted in the summary table below:

Outlet Barcode ID	Outlet Location	Outlet Type	Post-Remediation Follow-up Results (ppb)	Post-Remediation Follow-up Pass/Fail	Status
M09802	Classroom 153	Drinking Water Fountain - Bubbler	<5.0 or ≥5.0	Pass or Fail	Post-remediation follow-up testing complete. Outlet will (not)be placed back in service

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.