

**Department of Materials Management
Procurement Unit
MONTGOMERY COUNTY PUBLIC SCHOOLS
45 W. Gude Drive, Suite 3100
Rockville, Maryland 20850**

April 6, 2022


NOTICE TO BIDDERS

**The following are questions and responses regarding
IFB 9756.1, ADA Chairlift Replacements at Various Locations**

- Q. Has the design team verified that there are not lighting upgrades required at any of the schools to provide the required lighting? Light in Lift Area to Provide a Minimum of 5 Foot Candles.
- A. *Per Alban, we should be fine with the lighting levels.*
- Q. Has design team received Fire Marshal approval for installation of equipment on staircase at Walter Johnson?
- A. *Montgomery County – DPS has approved the building permit for the replacement in kind chairlift at Walter Johnson High School. There is a secondary set of stairs from the pit that can also be used in the event of an emergency.*
- Q. The lifts will require a phone connection. Can you please provide the location of the phone data room for each school OR an existing line in the vicinity of the lift that can be used for this purpose? This is something we'd like to look at during the scheduled site visits.
- A. *Contractor will need to run the lines to main phone room.*

All other terms and conditions remain the same.

The bid opening is scheduled for April 8, 2022 at 2:00 pm.



Angela McIntosh-Davis, CPPB, Team Leader
Procurement Unit

Please indicate your receipt of this notice by signing below and return with your bid or under separate cover.

Received: _____

Name and Title

Name of Company: _____

AMD:abb